

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

To,

Principal

Lala Ishar Dass Gumber DAV CENTENARY SR. SEC. PUBLIC SCHOOL, Railway Road, Jalalabad

No.: Abohar/2324/00096 Dated : 21/08/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 694 Dated: 14/08/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/08/2023. It is request to fill the attached feedback form and send it back to Block Water Testing Laboratory, Abohar

D/A : Test Report



Authorized Signatory
For, Block Water Testing Laboratory
Abohar

BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

TEST REPORT

Name & Address of Customer : Principal Lala Ishar Dass Gumber DAV CENTENARY SR. SEC. PUBLIC SCHOOL, Railway Road, Jalalabad		Customer Reference No.	No : 694 Dated : 14/08/2023			
		Sample Submitted by	Pardeep Kumar			
		Date of Sample Receipt	16/08/2023			
		Analysis Starting Date	16/08/2023			
		Analysis completion Date	21/08/2023			
Discipline : Chemical Testing		Group: Water				
ULR No.:		Sample Type :	Water			
Test Report No.:	Abohar/2324/00096	Date of Issue :	21/08/2023			
Registration no.:	Abohar/REG2324/00269	Condition of Sample :	Sealed			
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles			
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Lala Ishar Dass Gumber DAV CENTENARY SR. SEC. PUBLIC SCHOOL, Railway Road, Jalalabad (300ft) / NA			
Village :	Not Mentioned	Habitation :	Not Mentioned			
Block:	Not Mentioned	District :	Fazilka			
Latitude :	Not Mentioned	Longitude:	Not Mentioned			
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.25	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	350	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	1	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity	160	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness	120	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
9	Calcium	32	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
10	Magnesium	10	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method


BLOCK WATER TESTING LABORATORY, ABOHAR

Hanuman garh Road in Water works Near Bye pass, Abohar
priyanka_gorde@thinksmartsoft.com

11	Chloride	40	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
----	----------	----	-----	------	------	---

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.
6. Tempreture condition limit: 25±5°C and Humidity condition limit:50 ±20%



Mrs. Manju
Quality Manager
Authorized Signatory
For,Block Water Testing Laboratory
Abohar

----- End of the Test Report -----

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. DWTL-FZR/088/2024-25.Date: 14/02/2024.

It is certified that an inspection team headed by Harpreet Singh
Lab Chemist, Distt Water Testing Laboratory, Ferozpur (Name of Officers
with designation) from Water Supply & Sanitation Deptt, FZR (Name of
Department/Office) inspected the LIDG DAV Centenary
Sr. Sec. Public School, Railway Road, Talalabad (Name & Address of
the School) on 13-02-2024 and found that the LIDG DAV
Centenary Sr. Sec. Pub School (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central State/U.T. Govt.

The above valid for a period of one year i.e.14/02/2024 to 13/02/2025.

Harpreet Singh
14/02/2024
Lab Chemist/J.E. Incharge
Distt. Water Testing Laboratory
W/S & Sanitation Deptt.
Signature with Seal : Harpreet Singh
Name : Harpreet Singh
Designation : Lab Chemist

To

The Principal
LIDG DAV Centenary Sr. Sec. Public School,
Railway Road, Talalabad (W),
Distt. Faisalabad.
(Name & Address of the Institution)